



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(1276)

27 September 2016

Delabie Ltd.
21/F, On Hing Building,
1 On Hing Terrace,
Central, Hong Kong

(Attn.: Mr Sebastien Spriet)

Dear Sir,

Approval of "DELABIE" Self Closing Tap

Your letter ref. HK740 dated 29 August 2016 refers.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Delabie SCS

Country of Origin: France

Brand: Delabie

Details of Fitting: Self-closing, wall mounted, basin tap (chromium plated brass) incorporating spring loaded headwork and dome type operating member. The spout outlet incorporates a flow straightener & the product is supplied with plastic backnuts. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

Model: 741500

Size: ½" BSP male inlet

Marking: 'DELABIE' on operating member

WRAS Approval Number: 1303015

Installation Requirements: R001, R040

Expiry Date: 31 March 2018

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only