



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/13 Pt.1 T/J(310)

17 January 2014

Dynamic Building Material Co., Ltd.
Unit B3, Block B, 19/F,
Kailey Industrial Centre,
12 Fung Yip Street,
Chai Wan, Hong Kong

(Attn.: Mr Jackle HUI)

Dear Sir,

Approval of "DOUGLAS DELABIE" Combination Tap Assemblies

Your letter ref. DY-L1312001 dated 27 December 2014 refers.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Delabie SCS

Country of Origin: UK

Brand: Douglas Delabie

Details of Fittings: Single hole single outlet fixed thermostatic combination tap assemblies (chromium plated brass), incorporating a single, sequential thermostatic cartridge controlling both flow and temperature with a single lever operating member. Models: H9600 & H9605 are supplied spherical valves with plastic flow restrictors and all models incorporate a plastic flow straightener at the spout outlet. The Bioclip models have a detachable

body. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

- Models & Size:**
1. H9600 fixed & H9605 Bioclip
(stainless steel, PEX lined flexible hose assemblies incorporating 15mm compression connections)
 2. H9600610 fixed & H9605610 Bioclip
(10mm copper tails)

Marking: Delabie on operating member

WRAS Approval Number: 1209110

Installation Requirements: R001, R006, R010, R040

In view of the acceptance by WRAS, I have no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H
CHAN at tel. no. 2829 4453.

Yours faithfully,

A handwritten signature in dark ink, appearing to be 'L' with a small flourish at the end.

(C. M. LAM)
for Water Authority