



**Certificate number: 2106726**

Date issued 9th June 2021

Date expired 8th June 2026 Original/Amendment *Original*

## Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004  
Reference Standards: Regulators Specification  
Model Designations: see Appendix

### Factor: D Line.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,  
Business Unit Manager – Authorised Signatory  
Kiwa Watertec

CERTIFICATE

3901770301

**Kiwa Watertec**  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate issued to:**  
D Line  
Roskildevej 22  
2620 Albertslund  
Denmark



## UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2106726

---

The following products are covered by this certificate -

<b>PRODUCT DESCRIPTION</b> Range of wall mounted concealed manual blending valves with a brass body and ceramic cartridge headwork which control the flow and mixes the hot and cold water. Model QS3200 includes a diverter cartridge. Model QS3400 is a spout connector to be used in conjunction with models listed in this approval. ATS3 – Without Production Surveillance.
<b>MODEL(S)</b> QS3100 (single outlet); QS3200 ((two outlet); QS3400 (spout connector).
<b>SIZE:</b> 1/2" BSP(F).
<b>SCOPE:</b> Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C. Wall Mounted.
<b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.
<b>BACKFLOW PROTECTION NOTES</b> Consider balanced supplies or appropriate backflow protection at the inlets. Consideration must be made on installation to the airgap arrangement.
<b>MARKING</b> QT00 logo on EPDM sheet.
<b>ADDITIONAL NOTES</b> All water contact & exposed components satisfy opacity requirements.

**Extra Notes**